

**2016
Lead Compliance Test Results**

Rank	Collection Date	Lead (ppb)
1	7/14/16	ND <1.0
2	7/14/16	ND <1.0
3	9/15/16	ND <1.0
4	7/13/16	ND <1.0
5	7/13/16	ND <1.0
6	7/14/16	ND <1.0
7	9/14/16	ND <1.0
8	7/14/16	ND <1.0
9	7/14/16	ND <1.0
10	7/14/16	ND <1.0
11	7/14/16	ND <1.0
12	7/14/16	ND <1.0
13	7/13/16	ND <1.0
14	7/14/16	1.0
15	7/14/16	1.0
16	8/25/16	1.1
17	7/14/16	1.1
18	8/02/16	1.2
19	9/15/16	1.4
20	7/29/16	1.4
21	7/14/16	1.5
22	7/14/16	1.6
23	7/13/16	1.7
24	7/14/16	1.7
25	7/13/16	1.7
26	7/28/16	2.0
27	9/14/16	2.3
28	7/13/16	3.6
29	7/13/16	4.1
30	7/14/16	5.6

90th Percentile

SNEW is in compliance: 2.3 ppb
AL = 15 ppb; 90% of samples lower than AL

**2013
Lead Compliance Test Results**

Rank	Collection Date	Lead (ppb)
1	7/18/13	ND <1.0
2	8/15/13	1.1
3	7/18/13	1.2
4	7/18/13	1.4
5	7/17/13	1.4
6	7/18/13	1.5
7	7/18/13	1.5
8	7/17/13	1.5
9	7/17/13	1.6
10	7/17/13	1.6
11	7/18/13	1.6
12	7/18/13	1.8
13	7/18/13	2.0
14	7/18/13	2.1
15	7/18/13	2.2
16	7/18/13	2.4
17	7/19/13	2.5
18	9/18/13	2.7
19	7/17/13	2.9
20	7/18/13	2.9
21	7/18/13	2.9
22	8/15/13	3.2
23	7/18/13	3.2
24	7/17/13	3.4
25	7/18/13	4.1
26	7/18/13	4.8
27	9/04/13	5.0
28	7/18/13	6.0
29	7/17/13	7.4
30	7/18/13	8.9

90th Percentile

SNEW is in compliance: 5.0 ppb
AL = 15 ppb; 90% of samples lower than AL

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ppb: Parts per billion

ND: None detected

Please call the Water Operations laboratory at (203) 762-7884 ext. 4302 if there are any questions regarding these results.